



Product Service

CERTIFICATE

No. Z2 122205 0016 Rev. 00

Holder of Certificate: **Gokin Solar Co., Ltd.**

Room B25, 2/F, Building 4
No. 153 Rong'ao Road, Hengqin New District
519000 Zhuhai, Guangdong Province
PEOPLE'S REPUBLIC OF CHINA

Certification Mark:



Product:

Crystalline Silicon Terrestrial Photovoltaic (PV) Modules
Mono-Crystalline Silicon Photovoltaic module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 704062349441-00

Valid until: 2029-01-01

Date, 2024-01-02

(Zhulin Zhang)

CERTIFICATE

No. Z2 122205 0016 Rev. 00

Model(s):

GK-2-66HT-xxxM, xxx=670-700 in step of 5
GK-2-60HT-xxxM, xxx=610-635 in step of 5
GK-2-66HP-xxxM, xxx=650-670 in step of 5
GK-2-60HP-xxxM, xxx=590-610 in step of 5
GK-1-72HT-xxxM, xxx=560-590 in step of 5
GK-1-60HT-xxxM, xxx=465-490 in step of 5
GK-1-54HT-xxxM, xxx=420-445 in step of 5
GK-1-72HP-xxxM, xxx=540-560 in step of 5
GK-1-60HP-xxxM, xxx=450-465 in step of 5
GK-1-54HP-xxxM, xxx=405-420 in step of 5
xxx is standing for rated output power at STC

Parameters:

Construction:	Framed, with Junction box, Cable and Connectors.
Test Laboratory:	Changzhou HuaYang Inspection and Testing Technology Co., Ltd. No. 8 Lanxiang Road Wujin Economic Development Zone Changzhou, Jiangsu, China
Safety Class:	Class II
Maximum System Voltage:	1500 V DC
Fire Safety Class:	Class C according to UL790.

Tested according to:

IEC 61215-1:2021
IEC 61215-1-1:2021
IEC 61215-2:2021
IEC 61730-1:2023
IEC 61730-2:2023